

**HVAC SYSTEMS UPGRADE  
LYCOMING COUNTY PRISON  
RE-BID**

**ADDENDUM NO. 1**

**June 19, 2009**

**Page 1**

The contents of this Addendum alter and amend the drawings and specifications, and take precedence over the related items therein. Bidders shall include the cost of all items herein in their Proposals.

**DRAWINGS**

1. Drawing M-6: Add Note 6. Following the temporary relocation of the air compressor, remove the existing concrete pad.
2. Drawing M-7: FAN POWERED VAV BOX SCHEDULE: Change VAV-49 model to DTQS320208. Units No. VAV-12, 23, 24, 33, 48, and 53: Change inlet size to match the last two digits of the Model No.

END OF ADDENDUM