

BARTON & LOGUIDICE, D.P.C.

ADDENDUM NO. 2

TO

REQUEST FOR PROPOSALS

FOR

LEACHATE STORAGE TANK LINER PROJECT

LYCOMING COUNTY RESOURCE MANAGEMENT SERVICES
LYCOMING COUNTY, PENNSYLVANIA

TO ALL HOLDERS OF CONTRACT DOCUMENTS:

The attention of bidders is called to the following changes to the Request for Proposals and shall be taken into account in the preparation of proposals.

This Addendum is part of the Contract Documents in accordance with Article 6 and Article 7 of the AGREEMENT.

Bidders must acknowledge receipt of this Addendum No. 2 on page 1 of the Proposal Form in accordance with Attachment D, PROPOSAL FORM.

Questions at the Pre-Proposal Conference

Question		Response
1	Will a list of Pre-Proposal Conference Attendees be distributed?	The sign-in sheet (3 pages) is attached
2	Is a Bid Bond at 100% of project value required?	No, the RFP only requires a Performance and Payment Bond
3	Will the Proposal Opening be televised?	Commissioner Meetings are live streamed at http://www.lyco.org/Commissioners-Public-Outreach . Bid opening will probably be delayed until either November 5 or November 9 due to the General Election.
4	What is the required tank storage volume?	5.5 million gallons

5	What is the construction duration?	Contract Times are contained in Attachment F – Agreement, Article 2.02. Proposer can discuss schedule in their Technical Approach
6	Can the liner be less than 100 mil.?	Approved liners are contained in the permit. Alternative material will require approval from PA DEP
7	Has the tank ever been 100% dry?	Yes
8	Is water discharging from the underdrain system?	Yes, at times. Site visit included observation of the underdrain weir.
9	Is GCL required on the sidewalls?	Yes
10	Are the stairs required?	No
11	Are Barton & Loguidice (B&L) or Civil and Environmental Consultants (CEC) able to be on a Proposers team?	No, B&L and CEC are Owner's Engineer

BARTON & LOGUIDICE, D.P.C.



John J. Wood, P.E.
Senior Managing Engineer

ELECTRONIC TRANSMISSION – RETURN RECEIPT REQUESTED

PLEASE ACKNOWLEDGE BY RETURN EMAIL TO:
(sthompson@bartonandloguidice.com)

Signature: _____

Date: _____

Title: _____

Company: _____

29

LEACHATE STORAGE TANK LINER PROJECT
LYCOMING COUNTY RESOURCE MANAGEMENT SERVICES

1/3

Preproposal Conference

LCRMS Office, 447 Alexander Drive, Montgomery, PA 17752

October 7, 2020

1:30 pm

Firm Name	Contact	Telephone No.	Email
Mugilvie Enterprises	ALAN MUGILVIE	304 777 8787	AMUGILV@MUGILVIEENTR.COM
Babont Louidre	John Wood	717-341-1124	jwood@babontlouidre.com
Potter Enterprises	Paul Saylor	814-506-7092	psaylor@potterenterprises.com
Stone Hill Contracting	Bob Corvino	215-340-1840	estimating@stonehillcontracting.com
LCRMS	Steve Simms	570 337 5551	Steve.Simms@LCRMS.com

LEACHATE STORAGE TANK LINER PROJECT
 LYCOMING COUNTY RESOURCE MANAGEMENT SERVICES

Preproposal Conference

LCRMS Office, 447 Alexander Drive, Montgomery, PA 17752

October 7, 2020

1:30 pm

2/3

Firm Name	Contact	Telephone No.	Email
10 BAR Inc.	David Long	717-439-2828	David.L@10bar.com
AGERU	Don D'Guilio	704-505-5995	ddguilio@agruamerica.com
ALCO	Tim Waffler	1094994084	Tim@ALCOincUSA.com
BAI	Jim Echard	814 2382060	jechard@baigroupllc.com
ALCO	Matt Wintorle	609-468-4614	MattW@alcoincusa.com
NORTH d Co	Jason Bulke	484-225-3751	Jason.Bulke@northandcompany.com
WESTON ASSOCIATES	Justin Bergeron	330-407-3839	Justin@westonaccl.com

Firm Name	Contact	Telephone No.	Email
Plastic Fusion Fab.	Van Dobbs	256-746-1229	vdobbs@plasticfusion.com